

**MEMORANDUM FROM
DIRECTORATE OF REGENERATION AND ENVIRONMENT**

To:	Head Of Planning Services, Danum House	Our Ref:	MJ/CL
For the attention of:	Andrea Suddes	Your Ref:	12/00735
Copy to:		Date:	01/11/12
This matter is being dealt with by:	Mathew Julian	Extension	862601

Application No: 12/00735/FULM

Proposal: Erection of 12 apartments following demolition of existing meeting hall on approx 0.13ha of land.

Location: Place of Worship, Canterbury Road, Wheatley, Doncaster, DN2 4HT

Following receipt of a Phase 1 desktop assessment reference 12-10-02a for the above site and would provide the following comments.

I agree with the recommendations made within the report that gas protection measures inline with characterist situation 2 be installed and that made ground be removed from site.

Therefore I am satisfied that the development is unlikely to be affected by contamination and condition 3 can be discharged upon request.

Thank you

Mathew Julian (Pollution Control Officer)